



- 1 — STANDARD METER SPREAD (FACE TO FACE) 13 1/4" FOR 1 1/2" DIA. LINE, 17 1/4" FOR 2" DIA. LINE. COMPOUND METERS REQUIRE DIFFERENT SPACING. METER FLANGES SHALL BE BRASS ONLY
- 2 — FULL PORT BALL VALVES WITH PADDLOCK LOCKING DEVICE
- 3 — 24" X 24" ALUMINUM HATCH DOOR (BILCO J-1AL) OR EQUAL INSTALLED SQUARE TO STEPS
- 4 — METER PIT LOCATED AT PROPERTY LINE ON PRIVATE PROPERTY
- 5 — ALTERNATE DESIGNS MUST BE SUBMITTED FOR REVIEW AND APPROVAL TO COUNCIL BLUFFS WATER WORKS, DISTRIBUTION & METER DEPARTMENT PRIOR TO INSTALLATION.

<p>COUNCIL BLUFFS WATER WORKS</p>	
<p>STANDARD INSTALLATION PRECAST 1.5" & 2" WATER METER PIT (1.5" & 2" SERVICE LINE) (FOR OFF ROAD USE ONLY)</p>	
SCALE: NONE	DATE: 2/10/2010
FILE NAME: 1.5&2MTRPIT	