



NOTES:

1. MINIMUM 1 INCH WATER METER REQUIRED FOR ALL RESIDENTIAL FIRE SPRINKLER SYSTEMS.
2. ALL RESIDENTIAL FIRE SPRINKLER SYSTEMS SHALL BE LOCATED AFTER CBWW WATER METER.
3. SERVICE LINE SHALL BE INSTALLED TO STANDARD 1 INCH OR LARGER SERVICE LINE SPECIFICATION.
4. CONTACT THE COUNCIL BLUFFS BUILDING DIVISION, PLUMBING DEPARTMENT FOR BACKFLOW REQUIREMENTS AND REGULATIONS.
5. ALL WATER METERS MUST BE INSTALLED ACCORDING TO CBWW INSIDE WATER METER SPECIFICATIONS.
6. ALTERNATE DESIGNS MUST BE SUBMITTED FOR REVIEW AND APPROVAL TO THE COUNCIL BLUFFS WATER WORKS PRIOR TO INSTALLATION.

COUNCIL BLUFFS WATER WORKS



STANDARD RESIDENTIAL FIRE SPRINKLER SYSTEM METER INSTALLATION

NOT TO SCALE

DATE: 5/14/2021

FILENAME: DOMESTIC FIRE PROTECTION