

Department of Natural Resources

Public Water Supply - 2023 Lead and Copper Analysis Report

Lab ID #: 397

Lab Name: State Hygienic Laboratory

Lab Location: Ankeny

PWSID # IA 7820080

Name: Council Bluffs Water Works
 Address: 2000 N. 25th Street
 City, State: Council Bluffs, Iowa
 Zip: 51502-0156

ALL INFORMATION MUST BE CLEAR AND LEGIBLE

Lead 90th percentile

	Lead	Copper
EPA Method	200.8	200.8
DNR Code	126	126

This information derived from Utility.

(Utility)

Date Received by Lab	Sample Type	Sample ID	Sample Location (Street Address)	Collector (Name)	Collection Date	24-hr clock Time	Status	Sign	Lead Results (1030) mg/l	Sign	Copper Results (1022) mg/l	Date Analyzed	(lab use) Inits.	S/E/P (if needed)
06/20/23	D	8540			06/14/23	06:40		<	0.001		0.01	06/22/23		
06/20/23	D	8608			06/15/23	07:00		<	0.001		0.01	06/22/23		
06/23/23	D	7949			06/15/23	07:00		<	0.001		0.04	06/30/23		
06/23/23	D	2023-B			06/16/23	08:36		<	0.001		0.03	06/30/23		
06/23/23	D	18203			06/19/23	05:25		<	0.001		0.01	06/30/23		
06/23/23	D	18208			06/19/23	08:50		<	0.001		0.05	06/30/23		
06/23/23	D	18145			06/20/23	07:15		<	0.001		0.02	06/30/23		
06/20/23	D	2097			06/14/23	03:50		<	0.001		0.01	06/22/23		
06/30/23	D	18170			06/27/23	05:45		<	0.001		0.03	07/03/23		
06/20/23	D	6437			06/13/23	06:00		<	0.001		0.02	06/22/23		
06/30/23	D	8257			06/26/23	05:00		<	0.001		0.03	07/03/23		
06/30/23	D	8083			06/29/23	06:33		<	0.001	<	0.01	07/03/23		
06/30/23	D	18154			06/26/23	09:00		<	0.001		0.02	07/03/23		
06/30/23	D	151			06/23/23	06:18		<	0.001	<	0.01	07/03/23		
06/23/23	D	18040			06/19/23	07:05		<	0.001		0.05	06/30/23		
06/23/23	D	17931			06/15/23	07:15		<	0.001		0.05	06/30/23		
06/20/23	D	17940			06/14/23	05:45		<	0.001		0.02	06/22/23		
06/20/23	D	18097			06/14/23	05:34		<	0.001		0.05	06/22/23		
06/30/23	D	18101			06/26/23	05:20		<	0.001		0.02	07/03/23		
06/30/23	D	18105			06/29/23	07:50		<	0.001		0.03	07/03/23		
06/20/23	D	18132			06/14/23	05:35		<	0.001		0.02	06/22/23		
06/30/23	D	18207			06/23/23	05:18		<	0.001		0.02	07/03/23		
06/20/23	D	329			06/12/23	06:30			0.001		0.02	06/22/23		
06/23/23	D	305			06/16/23	06:30			0.001		0.02	06/30/23		
06/20/23	D	8378			06/14/23	06:45			0.002		0.02	06/22/23		
06/23/23	D	8579			06/22/23	05:30			0.002		0.03	06/30/23		
06/30/23	D	327			06/27/23	08:00			0.002		0.01	07/03/23		
06/20/23	D	8033			06/13/23	06:00			0.003		0.02	06/22/23		
06/23/23	D	2096			06/22/23	05:20			0.013		0.03	06/30/23		
06/30/23	D	17892			06/26/23	05:55			0.020		0.08	07/06/23		

90th Percentile:

Lead	0.002
Copper	0.050